

CERTIFICATE OF CONFORMITY

Issued to: Guangzhou Felicity Solar Technology Co., Ltd.
(Airport Baiyun)No. 2, 4, 6, 8, 10 and 12 Donghua Huaye Road, Renhe Town,
Baiyun District, Guangzhou, Guangdong, China

For the product: Hybrid Inverter

Trade name: 

Type/Model: IVGM10KLP3G1, IVGM12KLP3G1, IVGM14KLP3G1, IVGM15KLP3G1,
IVGM16KLP3G1, IVGM18KLP3G1, IVGM20KLP3G1

Ratings: See the annex

Manufactured by: Guangzhou Felicity Solar Technology Co., Ltd.
(Airport Baiyun)No. 2, 4, 6, 8, 10 and 12 Donghua Huaye Road, Renhe Town,
Baiyun District, Guangzhou, Guangdong, China

Requirements: VDE-AR-N 4105:2018-11
DIN VDE V 0124-100:2020-06

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 4947150.50.


The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 12 January 2031 or expires upon withdrawal of one of the above-mentioned standards.

Shanghai, 12 January 2026

Number: 4947150.01COC

DEKRA Testing and Certification (Shanghai) Ltd.



Rosa Zhou
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



DEKRA Testing and Certification (Shanghai) Ltd.

No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China

T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com

ESA-CER-F021 v4.1

PCA-141

Ratings of the PGU:

Model		IVGM 10KLP3G1	IVGM 12KLP3G1	IVGM 14KLP3G1	IVGM 15KLP3G1	IVGM 16KLP3G1
Battery	Battery type	Li-ion/Lead-acid				
	Battery Voltage Range [Vdc]	40 - 60				
	Rated Battery Voltage [Vdc]	50	50	50	50	50
	Max. charge/discharge current [A _{dc}]	210	240	260	280	300
	Max. charge/discharge Power [kW]	10	12	14	15	16
PV input	Max. PV input Voltage [Vdc]	800				
	Rated PV input Voltage [Vdc]	550				
	MPPT Voltage Range [Vdc]	160 - 650				
	Max. PV input current [A _{dc}]	26*2		36*2		
	Isc current [A _{dc}]	39*2		54*2		
	Max. PV input power [kW]	15.0	18.0	22.4	24.0	25.6
AC terminal (On-grid)	Rated AC Voltage [Vac]	220/380, 230/400V, 3W+N+PE				
	Rated Frequency [Hz]	50/60				
	Max. AC input current [A _{ac}]	16.7/16	20/19.2	23.4/22.4	25.0/24.0	26.7/25.6
	Max. AC input Power [kW]	11.0	13.2	15.4	16.5	17.6
	Rated AC output current [A _{ac}]	15.2/14.5	18.2/17.4	21.3/20.3	22.8/21.8	24.3/23.2
	Max. AC output current [A _{ac}]	16.7/16.0	20.0/19.2	23.4/22.4	25.0/24.0	26.7/25.6
	Rated AC output Power [kW]	10.0	12.0	14.0	15.0	16.0
	Max. AC output Apparent power [kVA]	11.0	13.2	15.4	16.5	17.6
	Power factor	0.8 leading to 0.8 lagging				
EPS output	Rated AC output Voltage [Vac]	220/380, 230/400V, 3W+N+PE				
	Rated Frequency [Hz]	50/60				
	Rated AC output current [A _{ac}]	15.2/14.5	18.2/17.4	21.3/20.3	22.8/21.8	24.3/23.2

Annex to 4947150.01COC

	Max. AC output current [Aac]	16.7/16.0	20.0/19.2	23.4/22.4	25.0/24.0	26.7/25.6
	Rated AC output Power [kW]	10.0	12.0	14.0	15.0	16.0
	Max. AC output Apparent power [kVA]	11.0	13.2	15.4	16.5	17.6
	Power factor	0.8 leading to 0.8 lagging				
General	Type of inverter	Non-isolated				
	Ingress Protection	IP65				
	Operating Temperature Range [°C]	-40 to 60 (Derating above 45 °C)				
	Net Weight [kg]	48.7				
	Size W×H×D [mm]	750*880*278				

Model		IVGM 18KLP3G1	IVGM 20KLP3G1
Battery	Battery type	Li-ion/Lead-acid	
	Battery Voltage Range [Vdc]	40 - 60	
	Rated Battery Voltage [Vdc]	50	50
	Max. charge/discharge current [Adc]	330	350
	Max. charge/discharge Power [kW]	18	20
PV input	Max. PV input Voltage [Vdc]	800	
	Rated PV input Voltage [Vdc]	550	
	MPPT Voltage Range [Vdc]	160 - 650	
	Max. PV input current [Adc]	36*2	
	Isc current [Adc]	54*2	
	Max. PV input power [kW]	28.8	32.0
AC terminal (On-grid)	Rated AC Voltage [Vac]	220/380, 230/400V, 3W+N+PE	
	Rated Frequency [Hz]	50/60	
	Max. AC input current [Aac]	30.0/28.7	33.4/31.9
	Max. AC input Power [kW]	19.8	22.0
	Rated AC output current [Aac]	27.3/26.1	30.4/29.0
	Max. AC output current [Aac]	30.0/28.7	33.4/31.9
	Rated AC output Power [kW]	18.0	20.0

Annex to 4947150.01COC

	Max. AC output Apparent power [kVA]	19.8	22.0
	Power factor	0.8 leading to 0.8 lagging	
EPS output	Rated AC output Voltage [Vac]	220/380, 230/400V, 3W+N+PE	
	Rated Frequency [Hz]	50/60	
	Rated AC output current [Aac]	27.3/26.1	30.4/29.0
	Max. AC output current [Aac]	30.0/28.7	33.4/31.9
	Rated AC output Power [kW]	18.0	20.0
	Max. AC output Apparent power [kVA]	19.8	22.0
	Power factor	0.8 leading to 0.8 lagging	
General	Type of inverter	Non-isolated	
	Ingress Protection	IP65	
	Operating Temperature Range [°C]	-40 to 60 (Derating above 45 °C)	
	Net Weight [kg]	48.7	
	Size W×H×D [mm]	750*880*278	

E.4 Unit certificate

Unit certificate		
Manufacturer / Address:	Guangzhou Felicity Solar Technology Co., Ltd. (Airport Baiyun)No. 2, 4, 6, 8, 10 and 12 Donghua Huaye Road, Renhe Town, Baiyun District, Guangzhou, Guangdong, China	
Type of power generation unit:	Hybrid Inverter IVGM10KLP3G1, IVGM12KLP3G1, IVGM14KLP3G1, IVGM15KLP3G1, IVGM16KLP3G1, IVGM18KLP3G1, IVGM20KLP3G1	
<input checked="" type="checkbox"/> Inverter	<input type="checkbox"/> Asynchronous generator	<input type="checkbox"/> Synchronous generator
<input type="checkbox"/> Stirling generator	<input type="checkbox"/> Fuel cell	<input type="checkbox"/> Others
Assessment values	Max. active power $P_{E_{max}}$	20.0 kW (IVGM20KLP3G1)
	Max. apparent power $S_{E_{max}}$	22.0 kVA (IVGM20KLP3G1)
	Rated voltage	230/400 V (3W+N+PE)
	Rated current (AC) I_r	29 A (IVGM20KLP3G1)
Network connection rule	VDE-AR-N 4105 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100) “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
Test report	4947150.50 from (2026-01-09)	
The above designated power generation unit meets the requirements of VDE-AR-N 4105.		

E.6 Certificate of the network and system protection

Certificate of NS protection	
Manufacturer	Guangzhou Felicity Solar Technology Co., Ltd. (Airport Baiyun)No. 2, 4, 6, 8, 10 and 12 Donghua Huaye Road, Renhe Town, Baiyun District, Guangzhou, Guangdong, China
Type of NS protection	Integrated NS protection
Central NS protection	<input type="checkbox"/>
Integrated NS protection	<input checked="" type="checkbox"/> Assigned to power generation unit of type: <u>IVGM10KLP3G1, IVGM12KLP3G1, IVGM14KLP3G1, IVGM15KLP3G1, IVGM16KLP3G1, IVGM18KLP3G1, IVGM20KLP3G1</u>
Network connection rule	VDE-AR-N 4105 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100) “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network
Test report	<u>4947150.50</u> from (2026-01-09)
The network and system protection designated above meets the requirements of VDE-AR-N 4105.	

E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection "Determination of electrical properties"		Report No.: 4947150.50	
Test report NS protection			
Type of NS protection:	<u>Integrated NS protection</u>	Other Manufacturer indications	
Software version:	<u>100</u>	N/A	
Manufacturer:	<u>Guangzhou Felicity Solar Technology Co., Ltd.</u> <u>(Airport Baiyun)No. 2, 4, 6, 8, 10 and 12</u> <u>Donghua Huaye Road, Renhe Town, Baiyun</u> <u>District, Guangzhou, Guangdong, China</u>		
Measuring period:	From <u>2025-11-11</u> to <u>2026-01-05</u>		
Inverter			
Protection function	Setting value	Tripping value	Tripping time NS protection*
Rise-in-voltage protection $U \gg$	$1.25 * U_n$	L1-N&L2-N&L3-N: 287.6 V L1-N: 287.5 V L2-N: 287.5 V L3-N: 287.5 V	L1-N&L2-N&L3-N: 139 ms L1-N: 138 ms L2-N: 137 ms L3-N: 136 ms
Rise-in-voltage protection $U >$	$1.10 * U_n$	$1.10 * U_n, \leq 100 \text{ ms}^{**}$	
Voltage drop protection $U <$	$0.8 * U_n$	L1-N&L2-N&L3-N: 184.0 V L1-N: 184.0 V L2-N: 184.0 V L3-N: 184.0 V	L1-N&L2-N&L3-N: 3.018 s L1-N: 3.039 s L2-N: 3.022 s L3-N: 3.039 s
Voltage drop protection $U \ll$	$0.45 * U_n$	L1-N&L2-N&L3-N: 103.8 V L1-N: 103.3 V L2-N: 103.4 V L3-N: 103.4 V	L1-N&L2-N&L3-N: 316 ms L1-N: 340 ms L2-N: 318 ms L3-N: 328 ms
Frequency decrease protection $f <$	47.5 Hz	47.50 Hz	131 ms
Frequency increase protection $f >$	51.5 Hz	51.48 Hz	174 ms
<p>*: The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch. When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above. The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms.</p> <p>** : Verification disconnection time of moving 10-min-average value. Disconnecting time as below: (496.00/501.00/509.00) s (L1-N/L2-N/L3-N from 600 s @ 100% U_n to 112% U_n) Continuous operation (L1-N/L2-N/L3-N from 600 s @ 100% U_n to 108% U_n) (300.52/305.00/311.00) s (L1-N/L2-N/L3-N from 600 s @ 106% U_n to 114% U_n)</p>			
<input checked="" type="checkbox"/> For integrated NS protection			
Assigned to power generation unit type	<u>IVGM10KLP3G1, IVGM12KLP3G1, IVGM14KLP3G1,</u> <u>IVGM15KLP3G1, IVGM16KLP3G1, IVGM18KLP3G1,</u> <u>IVGM20KLP3G1</u>		
Integrated interface switch type	Series-connected relays for all phase conductors each Relay type: CHAR-112A90C		
Response time of interface switch for integrated NS protection	Release time: max. 10 ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			<input checked="" type="checkbox"/>

--- End ---