Certificate No.: SGS/260312

CERTIFICATE OF SUITABILITY

This certificate is issued by **SGS Australia Pty Ltd** in accordance with the SGS Electrical Type Testing Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SGS certifies the electrical equipment described hereunder complies with the standard/s listed herein. It is a requirement that the electrical equipment supplied under this certificate shall be identical to the electrical equipment as certified.

CERTIFICATE HOLDER

Company Name: Guangzhou Felicity Solar Technology Co., Ltd.

Address: (Airport Baiyun) No.2, 4, 6, 8, 10 and 12 Donghua Huaye Road, Renhe Town, Baiyun District, Guangzhou, Guangdong, P. R. China

CERTIFICATION DETAILS

Certification Standards: AS/NZS 4777.2:2020 + A1 + A2 and IEC 62109-1:2010 and IEC 62109-2:2011

Comments/Conditions: Suitable for sale in Australia / New Zealand

Authorised Marking: SGS-260312-E

Certificate Issue Date: 23 April 2026

Certificate Expiry Date: 22 April 2031

ELECTRICAL EQUIPMENT

Description: Hybrid inverter

Trade Name	Model Number	Ratings
Felicitysolar	IVGM25KHP3G3	Input: PV:150-1000 V; PV: 30+30A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 36.3 A; 50 Hz; 25 kW; Class I
Felicitysolar	IVGM20KHP3G3	Input: PV:150-1000 V; PV: 30+30A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 29 A; 50 Hz; 20 kW; Class I
Felicitysolar	IVGM15KHP3G3	Input: PV:150-1000 V; PV: 30+20A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 21.7 A; 50 Hz; 15 kW; Class I
Felicitysolar	IVGM12KHP3G3	Input: PV:150-1000 V; PV: 30+20A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 17.4 A; 50 Hz; 12 kW; Class I
Felicitysolar	IVGM10KHP3G3	Input: PV:150-1000 V; PV: 20+20A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 14.5 A; 50 Hz; 10 kW; Class I
Felicitysolar	IVGM9K9HP3G3	Input: PV:150-1000 V; PV: 20+20A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 14.3 A; 50 Hz; 9.9 kW; Class I
Felicitysolar	IVGM8KHP3G3	Input: PV:150-1000 V; PV: 20+20A; Battery:160-700 V; Battery (max. charge/discharge):50+50 A; Output: 230/400 V; 11.6 A; 50 Hz; 8 kW; Class I

For and On Behalf of
SGS Australia Pty Ltd

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

JAS-ANZ

www.jas-anz.org/register

SGS Australia Pty Ltd
10/585 Blackburn Road, Notting Hill, 3168, Australia
www.sgs.com.au
Member of the SGS Group (SGS SA)