Ref: CS11357/1

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11357N

Particulars of Modification(s)

Addition of the following Hybrid Inverter models being similar to approved Model IVGM50KHP3G2 using the same control unit, control system, software, and similar hardware platform. The different powers are realized by software derating.

1. IVGM40KHP3G2 rated 40kW and equipped with two DC inputs and with four MPP trackers
2. IVGM30KHP3G2 rated 30kW and equipped with two DC inputs and three MPP trackers
3. IVGM29K9HP3G2 rated 29.9kW and equipped with two DC inputs and three MPP trackers
4. IVGM25KHP3G2 rated 25kW and equipped with two DC inputs and two MPP trackers

This certificate will expire on 04/02/2031.

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:
04 February 2026

For Secretary, Department of Customer Service

Electrical & Gas Approvals
PO Box 972, Parramatta NSW 2124
02 9372 8312

Email: energyapprovals@customerservice.nsw.gov.au
Website: www.fairtrading.nsw.gov.au